

Technical Data Sheet

Glastic® UTR Composite Tubing

Typical characteristics

- 1,000 Minutes Track Resistance, Electrically Insulating, Highly Flame Resistant, Low Smoke & Smoke Toxicity, UL® Recognized, and Halogen-Free
- Cost-Effective
- Dimensionally Stable

Typical industries

- Generator and Motor
- Dry transformers
- Electrical Industry
- Electrical Insulating Components
- Switchgear
- Electronics

Test method	Unit	Guideline value
NEMA LI-1		GPO-3
UL 746B	°C	130
UL 746B	°C	160
ASTM D 638	psi	30,700
ASTM D 638	psi X 10 ⁶	2.28
ASTM D 2412	lbs.	126
ASTM D 790	lbs.	134
ASTM D 1180	psi	1300
ASTM D 570	% by wt.	0.5
ASTM D 495	sec.	150
ASTM D 2303	min.	300
	NEMA LI-1 UL 746B UL 746B UL 746B ASTM D 638 ASTM D 638 ASTM D 2412 ASTM D 790 ASTM D 1180 ASTM D 570 ASTM D 495	NEMA LI-1 UL 746B °C UL 746B °C UL 746B °C ASTM D 638 psi ASTM D 638 psi X 10 ⁶ ASTM D 2412 lbs. ASTM D 790 lbs. ASTM D 1180 psi ASTM D 570 % by wt.

All of the information, suggestions, and recommendations pertaining to the properties and uses of the Röchling Glastic Composites products described herein are based upon tests and data believed to be accurate; however, the final determination regarding the suitability of any material described herein for the use contemplated, the manner of such use, and whether the use infringes any patents is the sole responsibility of the user. THERE IS NO WARRANTY, EXPRESS OR IMPLIED, INCLUDING, WITHOUT LIMITATION WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. Under no circumstances shall we be liable for incidental or consequential loss or damage. Glastic® is a registered trademark of Röchling Glastic Composites. UL® is a registered trademark of Underwriters Laboratories, Inc.

See correlating profile page for sizing and related information.

Roechling Industrial Cleveland, LP

4321 Glenridge Road • 44121 Cleveland/United States (US) • Tel. +1 216 486-0100 info@glastic.com • www.roechling.com/cleveland

Print: 27/07/2024 • Release: 20/09/2023 • Version: 1.0 PIM-Version: 48 • PIM-ID: 715324 • PIM-Code: 48-23-6.5.7-4.6.11.7.7.8-8

